



File: ULC Subj. C107
ULC-G5.2

January 4, 2005

CERTIFICATION BULLETIN 2005-1

To: Members of the Advisory Council of Underwriters' Laboratories of Canada
Listees of Nonmetallic Piping, Flammable Liquid, Underground
Others Interested

Subject: Nonmetallic Piping, Flammable Liquid, Underground (315 I14, QLXTC)

The purpose of this bulletin is to advise all interested parties of ULC's position with respect to nonmetallic underground piping and the new requirements of UL971 effective July 1, 2005.

UL971 was recently revised to include new and revised requirements in response to field problems in the USA with underground piping. These problems have also been reported in Canada, although up to now, to a lesser degree. ULC feels it is necessary that these updated requirements also be reflected in ULC requirements.

It is our intent to withdraw existing ULC piping ORD's and replace them with a single, new ORD that will be harmonized with UL971.

We expect to have this published no later than March 31, 2005 with an effective date of July 1, 2005.

Existing piping ORD's C107.4, C107.9, and C107.19 and products listed to these ORD's will be withdrawn effective July 1, 2005.

It is recognized that the effective date may not allow sufficient time for products to be submitted to ULC for investigation. However, since it is our intent to have harmonized requirements, product that has successfully been evaluated to the revised UL971 will be considered for ULC listing without additional testing.

.../2



ULC Subj. C107
ULC-G5.2

- 2 -

January 4, 2005

Current ULC Listee's under the subject category are requested to advise ULC prior to March 1, 2005 of their intent to continue ULC listing based on their UL investigation or to proceed to withdrawal.

Any questions concerning the above should be directed to Mr. Normand Breton, Chief Engineer, 416-757-3611 ext. 61238.



Normand Breton, P. Eng.
Regional Chief Engineer – Canada

Working for a safer world ...

