

REFRIGERATION NEWS & NOTES



January 2011

CORPORATE HEADQUARTERS
Underwriters Laboratories Inc.
333 Pfingsten Road
Northbrook, Illinois 60062-2096
Phone: 847-272-8800
Fax: 847-272-8129
E-mail: HVAC@us.ul.com

January 2011

REFRIGERATION NEWS & NOTES

If you have specific questions regarding this document, contact the following Staff:

North America
Karine Johnfroe, 847-664-3510
Engineering Manager
Karine.L.Johnfroe@us.ul.com
Fax 847-313-2890

North America
Randy Haseman, 847-664-3076
Principal Engineer (PDE)
Randall.J.Haseman@us.ul.com
Fax 847-313-3076

Asia
MoonGyung Kang
+ 86 512 6808 6400
MoonGyung.Kang@kr.ul.com

Europe
Giuseppe Barisan
+ 39 039 6410157
Giuseppe.Barisan@it.ul.com

UL Customer Service is available to assist you in the U.S. Monday through Friday 7:00 am – 7:00 pm Central Time at 877-UL-HELPS (877-854-3577) or worldwide at HVAC@us.ul.com

UL's Web Site is: www.ul.com or www.ul.com/hvacr

UL's Web Site provides access to the following topics:

- The UL Marks
- Global Resources
- UL product testing and certification, facility registration, and related services
- Commercial Inspection and Testing Services
- Seminars
- Technical information resources, such as Standards (including access to the Standards Electronic Bulletin Board System), Directories and UL's Data Services
- UL news and activities, including the latest news releases
- Information for regulatory authorities
- Management System Registration
- Consumer information
- CB Scheme and Market Access Solutions

TABLE OF CONTENTS

PAGE

Alternative Refrigerants..... 3

Other UL Services.....7

Environmental and Public Health Service.....7

Electromagnetic Compatibility Testing8

Efficiency and Performance Testing.....8

UL IQ™ for Plastics9

Verification Services.....9

Market Access Solutions..... 9

CB Scheme Certification11

Flammable Refrigerants..... 12

UL Classified Lubricant for use With Compressor Motor Insulating Materials and Refrigerants 13

UL’s Field Evaluation Service..... 14

Rebuilt Commercial Refrigerators, Beverage Coolers, and Beverage Cooler Dispensers14

Remanufactured Program for Refrigerant Motor Compressors 15

Pressure Strength Requirements for High Side Refrigerant Containing Parts16

Restricted Substances Compliance Solutions16

UL Standards.....16

UL Recognized Hermetic Refrigerant Motor Compressors to Hazardous Locations17

UL Listed Automotive Refrigerant Extraction Equipment17

UL Listed Automotive Refrigerant Recovery/Recycling Equipment19

UL Listed and Design Certified Commercial Refrigerant Recovery/Recycling Equipment 22

Performance Certified Commercial Refrigerant Recovery/Recycling Equipment..... 25

REFRIGERATION NEWS & NOTES

UNDERWRITERS LABORATORIES INC.

Alternative Refrigerants

- The EPA Ozone Protection Hotline is 800-296-1996 and has information on alternate refrigerants under the Significant New Alternatives Program (SNAP).

INTERNET: EPA's main web site is www.epa.gov
 EPA's SNAP web site is www.epa.gov/ozone/snap/index.html

- A list of refrigerants and their ASHRAE Classifications are tabulated below: Previously, refrigerants were Recognized by UL; they are now Classified to provide identification to the user of the refrigerant and to an authority having jurisdiction that the refrigerant has complied with the UL requirements. Note some refrigerants, including some blends, may be produced by more than one manufacturer.
- Refrigerants submitted to UL are investigated in accordance with requirements in UL's Standard for Refrigerants, UL 2182.
- See also page 12 for information on flammable refrigerants and Carbon dioxide as a refrigerant.
- Effective January 1, 1998, all production and packaged containers of Classified refrigerants must be marked with the Classified company name, product designation and the Classification Marking. Applicable Caution information may also be required. Also see the information on UL Packaging Program for Refrigerants and Refrigerant Oils.
- It is important to check the specific refrigerant supplier's name when you are identifying Classified refrigerants. Make sure to use refrigerant from a supplier who has UL Classification as indicated in UL's Electrical Appliance & Utilization Equipment Directory under the category Refrigerants (SLGV). To find refrigerants that have been Classified by UL, go to the [Online Certifications Directory](#) and search by company name or UL Category Code (SLGV).

| Refrigerants | | | | Minimum Design Pressures lb-in. ² Gauge (KPa) | | | | | |
|---------------|--------------------|-----------------|--|---|--------|--|------------------------|-------------------------|--------|
| UL Classified | Refrigerant Number | ASHRAE 34 Group | Refrigerant Composition/Name (Weight %)(++) (Trade Name) | Low Side | | High Side Water or Evaporatively Cooled | | High Side Air-Cooled | |
| | | | | Yes | R11 | A1 | Trichlorofluoromethane | 15 | (103) |
| Yes | R12 | A1 | Dichlorodifluoromethane | 85 | (586) | 127 | (876) | 169 | (1165) |
| No | R21 | B1 | Dichlorofluoromethane | 15 | (103) | 29 | (200) | 46 | (317) |
| Yes | R22 | A1 | Chlorodifluoromethane | 144 | (993) | 211 | (1455) | 278 | (1917) |
| Yes | R23 | A1 | Trifluoromethane | See Note 2 | | | | | |
| No | R30 | B2 | Methylene Chloride | 15 | (103) | 15 | (103) | 15 | (103) |
| No | R32 | A2 | Difluoromethane | 243 | (1673) | 403 | (2776) | 463 | (3189) |
| No | R40 | B2 | Methyl Chloride | 72 | (496) | 112 | (772) | 151 | (1041) |

| Refrigerants | | | | Minimum Design Pressures lb-in. ² Gauge (KPa) | | | | | |
|---------------|--------------------|-----------------|--|---|--------|--|--------|-------------------------|--------|
| UL Classified | Refrigerant Number | ASHRAE 34 Group | Refrigerant Composition/Name (Weight %)(++) (Trade Name) | Low Side | | High Side Water or Evaporatively Cooled | | High Side Air-Cooled | |
| Yes | R113 | A1 | Trichlorotrifluoroethane | 15 | (103) | 15 | (103) | 15 | (103) |
| Yes | R114 | A1 | Dichlorotetrafluoroethane | 18 | (124) | 35 | (241) | 53 | (365) |
| No | R115 | A1 | Chloropentafluoroethane | 152 | (1048) | 194 | (1338) | 252 | (1738) |
| Yes | R123 | B1 | Dichlorotrifluoroethane | 15 | (103) | 15 | (103) | 18 | (124) |
| Yes | R125 | A1 | Pentafluoroethane | 194 | (1333) | 281 | (1930) | 368 | (2528) |
| Yes | R134a | A1 | Tetrafluoroethane | 88 | (606) | 135 | (930) | 186 | (1282) |
| No | R152a | A2 | Difluoroethane | 76 | (523) | 119 | (820) | 164 | (1130) |
| No | R170 | A3 | Ethane | 616 | (4247) | 709 | (4888) | 709 | (4888) |
| Yes | R245fa+ | B1 | HFC-245fa (Genetron® 245fa) | See Notes 1 and 2 | | | | | |
| Yes | R290 | A3 | Propane | 129 | (889) | 188 | (1296) | 244 | (1682) |
| No | RC318 | -- | Octafluorocyclobutane | 34 | (234) | 59 | (407) | 85 | (586) |
| Yes | R401A | A1/A1 | R22/152a/124(53%/13%/34%) (SUVA® MP-39) | 85 | (586) | 133 | (917) | 182 | (1255) |
| Yes | R401B | A1/A1 | R22/152a/124(61%/11%/28%) (SUVA® MP-66, Genetron® MP-66) | 93 | (641) | 143 | (986) | 195 | (1344) |
| No | - | A1/A1 | R22/152a/124(40%/17%/43%) (SUVA® MP-33) | See Note 2 | | | | | |
| No | R401C | A1/A1 | R22/152a/124(33%/15%/52%) | See Note 2 | | | | | |
| Yes | R402A | A1/A1 | R22/125/290(38%/60%/2%) (SUVA® HP-80) | 183 | (1262) | 265 | (1828) | 347 | (2394) |
| Yes | R402B | A1/A1 | R22/125/290(60%/38%/2%) (SUVA® HP-81) | 170 | (1172) | 247 | (1730) | 324 | (2234) |
| No | 403A | A1/A1 | R290/22/218(5%/75%/20%) | See Note 2 | | | | | |
| No | 403B | A1/A1 | R290/22/218(5%/56%/39%) | See Note 2 | | | | | |
| Yes | R404A | A1/A1 | R125/143a/134a(44%/52%/4%) (Forane® 404A, SUVA® HP-62, Genetron® 404A) | 174 | (1200) | 253 | (1745) | 331 | (2281) |
| No | R405A | A1/A1 | R22/152a/142b/C318 (45%/7%/5.5%/42.5%)G2015 | See Note 2 | | | | | |
| No | R406A | A1/A2 | R22/600a/142b(55%/4%/41%)(GHG12) | See Note 2 | | | | | |
| No | - | - | R22/600a/142b(65%/4%/31%)(GHGHP) | See Note 2 | | | | | |
| Yes | R407A | A1/A1 | R32/125/134a(20%/40%/40%) (KLEA® 407A) | 177 | (1220) | 257 | (1771) | 335 | (2308) |
| Yes | R407B | A1/A1 | R32/125/134a(10%/70%/20%) (KLEA® 407B) | 186 | (1282) | 273 | (1881) | 355 | (2446) |
| Yes | R407C | A1/A1 | R32/125/134a(23%/25%/52%) (KLEA® 407C, SUVA® 9000, Forane® 407C, Genetron® 407C) | 167 | (1151) | 243 | (1674) | 320 | (2205) |

January 2011

| Refrigerants | | | | Minimum Design Pressures lb-in. ² Gauge (KPa) | | | | | |
|---------------|--------------------|-----------------|---|---|--------|--|--------|-------------------------|--------|
| UL Classified | Refrigerant Number | ASHRAE 34 Group | Refrigerant Composition/Name (Weight %)(++) (Trade Name) | Low Side | | High Side Water or Evaporatively Cooled | | High Side Air-Cooled | |
| Yes | R407D | A1/A1 | R32/125/134a(15%/15%/70%) (KLEA® 407D) | 116 | (797) | 180 | (1237) | 245 | (1683) |
| Yes | R407E | A1/A1 | R32/125/134a(25%/15%/60%) (KLEA® 407E) | See Note 2 | | | | | |
| Yes | R408A | A1/A1 | R22/143a/125(47%/46%/7%) (Forane® 408A, SUVA® 408A Genetron®408A) | 159 | (1096) | 233 | (1606) | 307 | (2116) |
| Yes | R409A | A1/A1 | R22/124/142b(60%/25%/15%) (Forane® 409A Genetron® 409A, SUVA® 409A) | 107 | (738) | 159 | (1096) | 212 | (1462) |
| No | R409B | A1/A1 | R22/124/142b(65%/25%/10%) | 113 | (776) | 168 | (1154) | 223 | (1532) |
| Yes | R410A | A1/A1 | R32/125(50%/50%) (Genetron® AZ-20, SUVA® 9100, Forane® 410A) | 238 | (1641) | 344 | (2372) | 449 | (3096) |
| No | R410B | A1/A1 | R32/125(45%/55%) | See Note 2 | | | | | |
| No | R411A | A1/A2 | R1270/22/152a (1.5%/87.5%/11%)(G2018A) | See Note 2 | | | | | |
| No | R411B | A1/A2 | R1270/22/152a(3%/94%/3%) (G2018B) | See Note 2 | | | | | |
| Yes | R411C+ | A1/A1 | R1270/22/152a(3%/95.5%/1.5%) (GREENCOOL G2018C) | 143 | (982) | 210 | (1443) | 277 | (1900) |
| No | R412A | A1/A2 | R22/218/142b(70%/5%/25%) (Arcton TP5R) | See Note 2 | | | | | |
| No | R413A | A1/A2 | R218/134a/600a(9%/88%/3%) (Isceon 49) | See Note 2 | | | | | |
| No | - | - | R125/134a/600(46.5%/50%/3.5%) (Isceon 59) | See Note 2 | | | | | |
| Yes | R414A+ | A1/A1 | R22/124/142b/600a (51%/28.5%/16.5%/4%)(GHG-X4) | See Note 2 | | | | | |
| Yes | R414B | A1/A1 | R22/124/142b/600a (50%/39%/9.5%/1.5%)(Hot Shot) | 101 | (694) | 151 | (1037) | 201 | (1380) |
| No | R415A | A2 | R22/152a(82%/18%) | See Notes 1 and 2 | | | | | |
| Yes | R416A | A1/A1 | R134a/124/600(59%/39.5%/1.5%) (FRIGC® FR-12) | See Notes 1 and 2 | | | | | |
| No | R417A | A1 | R125/134a/600 (46.6%/50%/3.4%) | See Notes 1 and 2 | | | | | |
| No | R418A | A2 | R290/22/152a (1.5%/96%/2.5%) | See Notes 1 and 2 | | | | | |
| No | R500 | A1 | R12/152a (73.8%/26.2%) | 102 | (703) | 152 | (1048) | 203 | (1399) |
| Yes | R502 | A1 | R22/115(48.8%/51.2%) | 162 | (1117) | 232 | (1599) | 302 | (2082) |
| No | R503 | | R23/13(40.1%/59.9%)(Freon® 503) | See Note 2 | | | | | |

| Refrigerants | | | | Minimum Design Pressures lb-in. ² Gauge (KPa) | | | | | |
|---------------|--------------------|-----------------|---|---|--------|--|--------|-------------------------|--------|
| UL Classified | Refrigerant Number | ASHRAE 34 Group | Refrigerant Composition/Name (Weight %)(++) (Trade Name) | Low Side | | High Side Water or Evaporatively Cooled | | High Side Air-Cooled | |
| | | | | | | | | | |
| Yes | R507 or R507A | A1 | R125/143a(50%/50%) (Genetron® AZ-50), S UVA® 507, Forane® 507) | 180 | (1242) | 262 | (1808) | 344 | (2374) |
| Yes | R508 or R508A | A1 | R23/116(39%/61%) (KLEA® 508, KLEA® 5R3) | See Note 2 | | | | | |
| Yes | R508B | A1/A1 | R23/116(46%/54%)(SUVA® 95) | See Note 2 | | | | | |
| No | R509 or R509A | A1 | R22/218(44%/56%) (Arcton TP5R2) | See Note 2 | | | | | |
| No | - | - | R134a/142b(79%/19%/2% Lubricant) (Freezone) | See Note 2 | | | | | |
| No | - | - | R134a/142b(80%/20%) (Freez-12) | See Notes 1 and 2 | | | | | |
| No | - | A2 | R32/134a(30%/70%) | See Notes 1 and 2 | | | | | |
| No | - | - | R23/22/152a(5%/90%/5%) (Moncton) | See Notes 1 and 2 | | | | | |
| No | R600 | A3 | N-Butane | 23 | (159) | 42 | (290) | 61 | (421) |
| Yes | R600a | A3 | Isobutane (Chevron Phillips Chemical Co. L P) | 39 | (269) | 63 | (434) | 88 | (607) |
| No | R611 | B2 | Methyl Formate | 15 | (103) | 15 | (103) | 15 | (103) |
| No | R717 | B2 | Ammonia | 139 | (958) | 215 | (1482) | 293 | (2020) |
| No | R744 | A1 | Carbon Dioxide | 955 | (6685) | 1058 | (7295) | 1058 | (7295) |
| No | R764 | B1 | Sulfur Dioxide | 45 | (310) | 78 | (538) | 115 | (793) |
| No | R1150 | A3 | Ethylene | 732 | (5047) | 732 | (5047) | 732 | (5047) |

Note 1: For other refrigerants, the minimum design pressure shall be no less than the saturation vapor pressure of the refrigerant at the following temperatures:

26.5°C (80°F) for low-sides.

51.7°C (125°F) for high-sides.

40.6°C (105°F) for water or evaporatively cooled high-sides.

Note 2: The design pressure need not be greater than the critical pressure of the refrigerant unless the critical temperature is exceeded under operating, standby or shipping conditions (DOT shipping conditions are 130°F). In which case the design pressure will be determined by the pressure at the operating conditions, standby conditions or 130°F whichever is highest. (Reference ASHRAE 15, Clause 9.2.2)

Note 3: For other refrigerants not listed, see the related standards Safety Standard for Refrigeration Systems, ASHRAE 15, and the Mechanical Refrigeration Code, CAN/CSA-B52.

+ Not yet Classified by ASHRAE 34, preliminary number.
++ For composition tolerances refer to ASHRAE-34.

- ASHRAE Classification – ASHRAE's Classification cannot be used until it is officially adopted by ASHRAE. See latest addendum for ASHRAE 34 for current status.
- ASHRAE 15 specifies that in evaluating the installation requirements of a product containing a refrigerant, the classification after the "/" under the ASHRAE 34 Group governs the application (i.e. a refrigerant rated A1/A2 is governed by the rules for A2 rated refrigerants). UL has developed safety requirements for products that use these refrigerants considering the fractionation potential in the application. Refer to the Subject: Flammable Refrigerants for more on fractionation.

Other UL Services

UL provides a full range of conformity and quality assessment services. UL also assists jurisdictional and provincial authorities, distributes educational materials, and works to enhance safety systems worldwide.

Environmental and Public Health Service

UL evaluates products and materials such as food service equipment, drinking water additives, drinking water system components and plumbing products in accordance with environmental and public health-effects standards. UL's certification programs for food service equipment and drinking water related products are accredited by the American National Standards Institute (ANSI). Products Classified for Environmental and Public effects are shown in the following UL Directories: *Drinking Water System Components, Component Materials and Treatment Additives; Classified Food Service Equipment; and Plumbing and Associated Products.*

January 2011

For more information concerning the certification of specific products covered in these directories, contact the following Staff or visit UL's related web site at www.ul.com/eph.

Drinking Water System Components, Component
Materials and Treatment Additives: Tom Bowman 847-664-3796

Classified Food Service Equipment:
Refrigeration: Andy Haulotte 847-664-2428
Commercial Cooking: Duane Johnson 847-664-2435

Electromagnetic Compatibility Testing

UL conducts a wide range of electromagnetic compatibility (EMC) tests on many electrical products. These tests include electromagnetic emissions and susceptibility evaluations.

For further information on EMC testing, visit www.ul.com/emc or contact customer service at 877-UL-HELPS (877-854-3577).

Efficiency and Performance Testing

Some products are required to conform to certain requirements or specifications related to their function, such as those designed for purposes of lighting, heating, cooling, communications or other functions. UL can investigate these products for compliance to applicable performance requirements or specifications.

Subject: Efficiency Performance Testing for the California Energy Commission

In our continuing effort to offer our customers "one-stop shopping," UL is accredited to perform energy efficiency testing according to the California Code of Regulations Title 20, Chapter 2 Subchapter 4: Energy Conservation Article 4: Appliance Efficiency Regulations. The accreditation allows UL to test and submit data to the California Energy Commission (CEC) for manufacturers intending to supply self-contained commercial refrigerators and freezers and refrigerated vending machines for use in the state of California. Contact: Contact Mike Shows at 972-509-1281 or Todd Oliphant at 972-509-1285.

Subject: Energy Efficiency of Electrical Appliances sold in Canada

UL's Energy Verification program is accredited by Natural Resources Canada. Commercial Refrigerators, Freezers, Ice Makers, Dehumidifiers, and Vending Machines may be evaluated to the appropriate standards and regulations, resulting in a UL Energy Verification Mark. The Mark is accepted throughout Canada. Testing may be conducted at UL or at the manufacturer's facilities under UL's Data Acceptance Program. Contact Mike Shows at 972-509-1281 or Todd Oliphant at 972-509-1285.

UL IQ™ for Plastics

UL IQ™ for Plastics brings UL's Plastics Recognized Component Directory to a searchable [online database](#) that will allow you to verify UL Recognition for plastics or to search for UL Recognized plastics by:

- product specifications
- company name
- file number
- generic family name
- grade and
- description.

Updated regularly, the information in UL IQ™ for Plastics is available online 24 hours a day at www.ul.com/plastics.

Verification Services

UL Verification Services offers commercial testing, commercial inspections, commercial auditing/assessment and supply chain services geared to customer requirements.

As part of its services, UL Verification Services inspects products at the supplier's location, during the manufacturing process and prior to shipment. It tests products to a manufacturer's specific criteria test for safety, performance, verification, reliability and design validation, or to a national or international standard. It performs supplier assessment to client's quality requirements, as well as for social accountability and environmental practices. In addition to these services, UL Verification Services also offers supply chain services, such as identification of product requirements, inspection and testing to those requirements, assistance in the development and maintenance of the supply chain, and Internet-based data reporting and tracking. For the solutions you need, please contact the UL Verification Services Staff at 847-272-8800.

International Certification and Market Access Solutions

- UL offers a CE Marking Assistance Program which includes:
 - identification of applicable directives, critical elements, and their effective date,
 - description of the methods of conformity assessment available under each directive
 - identification of applicable documentation requirements
 - identification of published European Norm (EN) standards that can be used to verify compliance
- UL can facilitate testing and/or product certification and obtain appropriate documentation as required by the directives through UL's relationships with various European organizations.
- EU Directive Self-Declaration Testing Assistance

For products covered under Directives which allow for manufacturer's self-declaration, UL can perform tests to the appropriate European standards, provide test results, assist in the preparation of the required technical file and assist in the preparation of the "Declaration of Conformity."

- If you need more specific information about your product and how UL can help you with your European or International conformity assessment needs, contact your UL engineer or the following engineers from Conformity Assessment Services for assistance:

Commercial Cooking Equipment

Duane Johnson (Commercial Cooking)
Telephone: 847-664-2435; Fax: 847-313-2435
E-mail: Duane.T.Johnson@us.ul.com

Hearth Products

Bob Zimmerman Jr. (Hearth Products)
Telephone: 847-664-3129; Fax: 847-509-6225
E-mail: Robert.J.Zimmerman.Jr.@us.ul.com

Air Conditioning Equipment and Electrical Controls

Paul Jackson (Controls)
Telephone: 847-664-1774
E-mail: Paul.K.Jackson@us.ul.com

Fred Salzman (AC Equipment)
Telephone: 847-664-3002; Fax: 847-509-6225
E-mail: Frederic.A.Salzman@us.ul.com

Refrigeration Equipment, Room Air Conditioners, and Motor-Compressors

Andy Haulotte (Refrigeration Equipment)
Telephone: 847-664-2428; Fax: 847-509-6225
E-mail: Andrew.H.Haulotte@us.ul.com

Mike Romano (Motor Compressors)
Telephone: 847-664-2167; Fax: 847-509-6225
E-mail: Michael.A.Romano@us.ul.com

Joe Freeman (Room Air Conditioners)
Telephone: 847-664-2937; Fax: 847-509-6225
E-mail: Joseph.P.Freeman@us.ul.com

Laundry Equipment and Household Cooking Appliances

Duane Johnson
Telephone: 847-664-2435; Fax: 847-509-2435
E-mail: Duane.T.Johnson@us.ul.com

You can get additional information at www.ul.com/international.

CB Scheme Certification Helps Facilitate International Trade

UL participates in the International Electrotechnical Committee for Conformity Testing to Standards for Electrical Equipment (IECEE) Certification Body (CB) Scheme for many categories, including the following:

- Household Refrigerators, IEC 60335-2-24
- Motor-Compressors, IEC 60335-2-34
- Air Conditioning Equipment, IEC 60335-2-40
- Dispensing Appliances and Vending Machines, IEC 60335-2-75
- Commercial Refrigerators, IEC 60335-2-89
- Switches for Appliances, IEC 61058
- Controls, IEC 60730
- Process Control Equipment, IEC 61010
- Thermal Links (Thermal Cutoffs), IEC 60691

The CB Scheme, established by the IECEE, provides a means for the mutual acceptance of CB Test Certificates and Reports among participating safety certification organizations in certain product categories. It is an international network made up of product certification organizations in 38 countries throughout North America, Latin America, Europe, Africa, Australia and Asia. National Certification Bodies (NCBs) worldwide expedite this certification process.

UL's Northbrook engineers can prepare CB Test Reports and have CB Test Certificates issued for the equipment categories noted above.

Software and IEC 61508 – UL also provides assistance to manufacturers with the generation of informative test reports for demonstrating compliance with IEC 61508, Functional Safety of Electrical/Electronic/Programmable Electronic Safety-Related Systems, pending participation into the CB Scheme.

For more information on the CB Scheme certification for these categories please contact the following staff at the Northbrook Office:

Refrigeration and Air Conditioning Equipment – Andy Haulotte at 847-664 2428 or email at Andrew.H.Haulotte@us.ul.com

Compressors –Mike Romano at 847-664-2167 or e-mail at Michael.A.Romano@us.ul.com

Switches – Judy Duresa at 847-664-2592 or e-mail at Judy.A.Duresa@us.ul.com

Controls – Leo Yermakov at 847-664-1580 or e-mail at Leonid.Yermakov@us.ul.com

Process Control Equipment – Leo Yermakov at 847-664-1580 or e-mail at Leonid.Yermakov@us.ul.com

Thermal Links – Thomas DeGrande at 847-664-2684 or e-mail at Thomas.A.Degrande@us.ul.com

Software and IEC 61508 – Anura S. Fernando at 847-664-1730 or e-mail at Anura.S.Fernando@us.ul.com

Flammable Refrigerants

- UL has worked with the Household Refrigerator and Freezer Industry and the IEC (SC61C) in a continuing effort to develop requirements for Household Refrigerators and Freezers employing flammable refrigerants or refrigerants that can fractionate to a flammable gas (e.g. A1/A2). The requirements were adopted in August 2000 as a supplement to the UL Standard for Household Refrigerators and Freezers, UL 250. The UL requirements are similar to the IEC requirements for 60335-2-24 which were adopted in June 1997.
- UL worked with the Commercial Refrigerator and Freezer Industry to develop requirements for Commercial Refrigerators and Freezers employing flammable refrigerants. These requirements have been published, and UL has Listed several commercial refrigerators and freezers that employ propane as the refrigerant. The UL requirements are similar to the requirements in IEC 60335-2-89.
- Fractionation: Refrigerant blends that employ a flammable component have been analyzed for fractionation in accordance with UL 2182. It is commonly believed that operating conditions related to the pressure and temperature of the blend in an end-use application will not result in a “worse” fractionation scenario. Equipment that includes receivers and accumulators may require a check test to confirm that if a leak occurs in that area (i.e., if a joint is present or damage can occur), a flammable gas will not be leaked.
- UL has determined for 410A and 407C that there will not be fractionation within the equipment that is more than what was evaluated during the investigation of the refrigerant per UL 2182.
- For further information contact Randy Haseman 847-664-3076

Carbon Dioxide (R744) as a Refrigerant

- A Joint Task Group (JTG) was formed for the purpose of drafting requirements for large-scale refrigeration equipment using R744 (CO₂) as the refrigerant. The JTG was comprised of representatives from equipment manufacturers, UL, and other safety organizations. Requirements have been published in several of the affected UL standards, including UL 471, the Standard for Commercial Refrigerators and Freezers and UL 1995, the Standard for Heating and Cooling Equipment. The requirements are based on a revision to clause 9.2.6 of ASHRAE 15. Current designs of such equipment use the refrigerant in a sub-critical manner, so the proposed requirements are **not** intended to cover the use of CO₂ in transcritical applications.
- For further information contact Randy Haseman 847-664-3076.

UL Classified Lubricant For Use With Compressor Motor Insulating Materials and Refrigerants

- UL has developed specifications to Classify lubricant used in sealed motor compressors of air conditioning and refrigeration equipment. The new lubricants are synthetic with varied chemical additives and viscosities to enhance their performance.
- The lubricants are evaluated according to the requirements in Subject 984A, Outline of Investigation for Compatibility of Insulating Materials and Refrigerant/Oil for Use in Hermetic Refrigerant Motor-Compressors. Additional details can be found in UL's November 18, 1997 Bulletin under Subject 984A.
- This UL program covers the Classified lubricants along with the indicated refrigerants for all insulating materials used in Recognized Hermetic Refrigerant Motor-Compressors. Classified Refrigerant Oils are shown in the current Electrical Appliance & Utilization Equipment Directory under the category Refrigerant Oils (SOLI). For further information please contact Mike Romano (Ext. 42167).
- UL's Classification Marking (shown below) on the product is the means to identify products which have been evaluated under this program.



As to compatibility with Classified Refrigerants specified on the shipping container and motor electrical insulating materials used in Recognized Hermetic Refrigerant Motor-Compressors

The following oils are presently Classified under UL's Program:

| Classified Company | UL File No. | Lubricant Designation | Lubricant Type | Refrigerant |
|-----------------------------------|-------------|--|-------------------------|---|
| CPI Engineering | SA11535 | Solest 31-HE, Solest 370, Solest 22-BC, Solest LT-32, Solest 32-BC, Solest 46, Solest 68, Solest 68FA, Solest 120, Solest 170, Solest 180, Solest 220, Solest 72, Solest 320; CP, -2915AS, -2922LE, -2921, -2931, EXP-1828 | POE | R22, R134a, R404A, R407A, R407B, R407C, R410A, R507 and R507A |
| | | Type 32MAPOE-DA. | POE | R22, R134a, R404A, R407A, R407B, R407C and R410A |
| | | CP-2910, -2910A, -2922E | POE | R134A |
| | | RL68H, RL68S | POE | R22, R134a, R404A, R407A, R407B, R407C, R410A, R507 and R507A |
| | | DE 10028, DE 10029, RL7H, RL10H, RL15EB, RL15H, RL22H, RL22N, RL32H, RL32HB, RL32S, RL46H, RL46HB, RL46S, RL68HB, RL100, RL100S, RL150S, RL170H, RL220H | | R134a, R404A, R407A, R407B, R407C, R410A, R507 and R507A |
| Lubrizol | SA9881 | Lubrikuhl Lubrizol 2916S | POE | R134a, R404A |
| Hatco | SA11574 | EAL Artic 22, 32, 32ST, 46, 68, 100, 150 and 220 | POE | R134a, R404A, R407A, R407B, R407C, R410A, R507, and R507A |
| | | EAL Artic 15 | POE | R134a |
| Shrieve Chemical Co. | SA32640 | Zerol 150T | Alkyl-Benzene Synthetic | R22 |
| Japan Energy | SA11855 | Freol Alpha 10, 10E, 10L, 10LL, 10SZT, 10W and 22E | POE | R134a |
| Idemitsu Kosan Co. Ltd. | SA11970 | Daphne Hermetic FV10 through FV120 | PVE | R134a, R404A, R407A, R407B, R407C, R410A, R507 and R507A |
| Idemitsu Lubricants America Corp. | SA32168 | Daphne Hermetic FV10-FV120 | PVE | R134a, R404A, R407A, R407B, R407C, R410A, R507 and R507A |


UL's Field Evaluation Service

- Regulatory authorities occasionally find products in the field that haven't been investigated by a third-party certification organization. It can be difficult for regulatory authorities to determine the acceptability of these products without safety certification markings. UL has established a program to evaluate installed products in the field to assist regulatory authorities in determining their acceptability. Under this program, UL technical staff conducts on-site safety evaluations including testing, examination and installation review of products that have already been installed. If the product complies with UL's safety requirements, a Field Evaluated Product Mark is applied to the product on the spot. Contact UL at 877-UL-HELPS (877-854-3577).

Rebuilt Commercial Refrigerators, Beverage Coolers, and Beverage Cooler Dispensers

- UL has a program for Listing reconditioned or "rebuilt" commercial refrigerators, beverage coolers, and beverage cooler dispensers. These rebuilt products are factory reconditioned by being disassembled, then reassembled and tested using new or reconditioned components to provide a product equivalent to a new or original product. Manufacturers interested in using this service are encouraged to contact UL's Customer Service Department.

Remanufactured Program for Refrigerant Motor Compressors

- UL has evaluated remanufactured refrigerant motor-compressors and remanufactured refrigerant open type compressors. These remanufactured products comply with the same requirements as new compressors. Remanufactured compressors used in the field should be checked for the  Recognition Mark or the UL Listing Mark. Remanufactured compressors without the appropriate marking may not meet requirements of local electrical codes.
- Remanufactured compressors might be used in air conditioning and refrigeration condensing units, compressor units, commercial refrigerators and freezers, ice makers, ice cream makers, etc.
- The following remanufactured compressors are presently covered by UL's Program:

| Recognized Remanufactured Hermetic Refrigerant Motor Compressors (SLLG2) | | Listed Remanufactured Open Type Refrigerant Compressors (SLRG) | |
|--|-------------|--|-------------|
| Company Name | UL File No. | Company Name | UL File No. |
| Aircondex Inc. | SA11585 | York Refrigeration | SA2792 |
| Emerson Climate Technologies. | SA2337 | * | |
| * | | | |
| | | Trane Co. | SA11512 |
| * | | | |
| Trane Co. | SA11511 | | |
| York International Corp. | SA9732 | | |
| Carlyle Stone Mountain | SA12668 | | |
| York Refrigeration | SA12484 | | |

Pressure Strength Requirements For High Side Refrigerant Containing Parts

- Some new refrigerants entering the marketplace operate at higher pressures than their predecessors. Therefore, it is necessary to either revise the refrigerant containing end product standards to conduct tests at these higher pressures or to conduct fatigue analysis on these refrigerant containing products. UL worked with an ARI task force to develop the requirements for the Fatigue Test Analysis to provide an alternate means of evaluating the strength of parts subjected to refrigerant pressure. The requirements are published in UL's Standards for Refrigerant-Containing Components and Accessories, UL 207, Heating and Cooling Equipment, UL 1995, and Commercial Refrigerators and Freezers, UL 471.

UL's Restricted Substances Compliance Solutions

- If you manufacture electrical products or components, you are probably aware of the increasing concerns about the use of hazardous substances in your products. Many regions are adopting or considering regulations on hazardous substances. UL's Verification Services can assist you with training or third party testing for restricted substances. For further information, contact UL's Customer Service Department at 877-UL-HELPS (877-854-3577) or cec@us.ul.com.

UL Standards:

- UL Certification customers can access UL and ULC Standards on our web site at no charge. Sales of UL Standards are available at www.comm-2000.com. For additional information, visit www.ul.com/standards.

UL Recognized Hermetic Refrigerant Motor Compressors For Hazardous (Classified Locations)

- To assist manufacturers, users and local authorities having jurisdiction, UL created the product category “Hermetic Refrigerant Motor-Compressors For Use In Hazardous (Classified) Locations” (MPAH2) under the Component Recognition Program.

Products covered in this category are intended to be used in hazardous locations refrigeration and air conditioning equipment such as refrigerators, freezers, air conditioners, water coolers and the like. UL 1203, the Standard for “Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations,” along with UL 984, the Standard for “Hermetic Refrigerant Motor-Compressors,” are used to investigate products in this category.

Contact Francis Mah at 847-664-2842 for more details. Presently, equipment of this type is Recognized for:

| <u>Company</u> | <u>UL File No.</u> |
|----------------------------|--------------------|
| Andover Protection Systems | E185636 |

UL Listed Automotive Refrigerant Extraction Equipment

- These Listings cover automotive refrigerant extraction equipment intended to remove refrigerant from automotive refrigerant systems.
- This equipment has been evaluated to determine that it meets the extraction specifications for R-12 recovery to assure that venting of refrigerant will not occur. The refrigerant removed by this equipment is intended to be returned to a refrigerant reclamation facility for processing. Such equipment is provided with the auxiliary marking “Design Certified by Underwriters Laboratories Inc. to meet SAE J2209 (date) for use with R-12. The refrigerant from this equipment must be processed to ARI Standard 700-88 before reuse in a mobile air conditioning system.” This marking indicates that the equipment has been investigated for compliance with the applicable SAE requirements.
- The basic standard used to investigate products in this category is UL 1963, “Refrigerant Recovery/Recycling Equipment.”
- The Listing Mark of Underwriters Laboratories Inc. on the product is the only method provided by UL to identify products manufactured under its Listing and Follow-Up Service. The Listing Mark for these products includes the name and/or symbol of Underwriters Laboratories Inc. together with the word “Listed,” a control number, and the following product name: “Automotive Refrigerant Extraction Equipment.”

THE FOLLOWING TABULATES
AUTOMOTIVE REFRIGERANT EXTRACTION EQUIPMENT (SCHL). FOR MOBILE
AUTOMOTIVE AIR CONDITIONING SYSTEMS. EQUIPMENT INTENDED TO RECOVER
R12 IS MARKED: "DESIGN CERTIFIED BY UNDERWRITERS LABORATORIES INC. TO
MEET SAE-J2209 (DATE) FOR USE WITH R-12. THE REFRIGERANT FROM THIS
EQUIPMENT MUST BE PROCESSED TO ARI STANDARD 700-88 BEFORE REUSE IN A
MOBILE AIR CONDITIONING SYSTEM". EQUIPMENT INTENDED TO RECOVER R134a
IS MARKED: "DESIGN CERTIFIED BY UNDERWRITERS LABORATORIES INC. TO
MEET SAE-J1732 FOR USE ONLY WITH R134a. THE REFRIGERANT FROM THIS
EQUIPMENT MUST BE PROCESSED TO ARI 700-93 SPECIFICATIONS OR TO
SAE-J2210 SPECIFICATIONS BY USING DESIGN CERTIFIED EQUIPMENT OF THE
SAME OWNERSHIP."

| <u>R-12 Manufacturers</u> | <u>R-12 Models</u> |
|---|----------------------|
| SPX Corporation, Robinair Division | 17625A |
| <u>R-134a Manufacturers</u> | <u>R-134a Models</u> |
| SPX Corporation, Robinair Div. | 34650 |
| Van Steenburg Engineering Laboratories Inc. | JV90R-R134a |

THE FOLLOWING TABULATES
AUTOMOTIVE REFRIGERANT RECOVERY/RECYCLING EQUIPMENT (SCMA) EMPLOYING
A COMMON REFRIGERANT SYSTEM FOR CFC-12 OR HFC-134a IN MOBILE AUTOMOTIVE
AIR CONDITIONING SYSTEMS "DESIGN CERTIFIED BY UNDERWRITERS LABORATORIES
INC. TO MEET SAE-J1770 (DATE) FOR RECYCLING R-12 AND R134a USING COMMON
REFRIGERANT CIRCUITS."

| <u>Manufacturer</u> | <u>Model</u> |
|---------------------|--------------|
| SPX Corporation | 17800B, |

UL Listed Automotive Refrigerant Recovery/Recycling Equipment

- This equipment has been evaluated to determine the minimum purity specifications for recycled CFC-12 or HFC-134a for use in mobile automotive air conditioning systems. Such equipment is provided with the following auxiliary marking "Design Certified by Underwriters Laboratories for Compliance with 'SAE-J1991' for CFC-12 or 'SAE-J2210' for HFC-134a (date)" to indicate that the equipment has been investigated for compliance with the applicable SAE requirements.
- These Listings cover refrigerant recovery/recycling equipment used to service automobiles, light trucks, and other vehicles with air conditioning systems that employ CFC-12 or HFC-134a as a refrigerant. This equipment is intended to be used mainly in automotive service stations and repair facilities.
- The use of this equipment to service mobile vehicles for refrigerated cargo that have hermetically sealed, rigid-pipe air conditioning systems has not been investigated.
- The equipment has not been investigated for operation in hazardous locations. This equipment is to be marked for use either (1) in rooms with mechanical ventilation that provides at least four air changes per hour, or (2) located at least 18 in. (457 mm) above the floor.
- The basic standard used to investigate products in this category is UL 1963, "Refrigerant Recovery/Recycling Equipment."
- Equipment intended only for testing or charging air conditioning systems of mobile vehicles is covered under the category of Garage Equipment (JGWV).

- The Listing Mark of Underwriters Laboratories Inc. on the product is the only method provided by UL to identify products manufactured under its Listing and Follow-Up Service. The Listing Mark for these products includes the name and/or symbol of Underwriters Laboratories Inc. together with the word "Listed," a control number, and the following product name: "CFC-12 Recycling Equipment" or "HFC-134a Recycling Equipment."

THE FOLLOWING TABULATES
REFRIGERANT RECOVERY/RECYCLING EQUIPMENT, AUTOMOTIVE (SCMA) FOR
MOBILE AUTOMOTIVE AIR CONDITIONING SYSTEMS USING CFC-12 "DESIGN
CERTIFIED BY UNDERWRITERS LABORATORIES INC. FOR COMPLIANCE WITH
SAE-J1991 (DATE)."

| <u>Manufacturer</u> | <u>Model</u> |
|-------------------------------------|--|
| SPX Corporation | 17700Z |
| Van Steenburgh Engineering Lab Inc. | * JV90-4, -3, -2, -1, LV30-4, -3, -2, -1, CV15-4, -3, -2, -1 |

THE FOLLOWING TABULATES
 REFRIGERANT RECOVERY/RECYCLING EQUIPMENT, AUTOMOTIVE (SCMA) FOR
 MOBILE AUTOMOTIVE AIR CONDITIONING SYSTEMS USING HFC-134a "DESIGN
 CERTIFIED BY UNDERWRITERS LABORATORIES INC. FOR COMPLIANCE WITH
 SAE-J2210 (DATE) or SAE-J2788."

| Manufacturer | Model |
|-----------------|--|
| SPX Corporation | 34288(+),34788(+), 543160(+), 545160(+), AC34288(+), AC34788(+), H234288(+), H234788(+), J-48943(+), RA-C34788(+), RA-C324288(+), ROB134APF(+), 48920, GE-48800 34988(+), 48710(+) |

*

(+)- Tested in accordance with SAEJ2788.

MULTIPLE LISTINGS

| Company | Model |
|---------|-------|
|---------|-------|

*

| | |
|---------------|---------------------------|
| Snap-On Tools | EEAC324A (+), EEAC325A(+) |
|---------------|---------------------------|

UL LISTED AND DESIGN CERTIFIED COMMERCIAL REFRIGERANT RECOVERY/RECYCLING EQUIPMENT

These Listings cover refrigerant recovery/recycling equipment intended to remove and recycle refrigerant from residential and commercial refrigerant systems. This equipment has been evaluated for the tabulated performance characteristics. Equipment manufactured prior to November 15, 1993 is provided with an auxiliary marking "Design Certified by Underwriters Laboratories Inc. In Accordance With ARI 740 (date) For The Tabulated Characteristics" to indicate that the equipment has been investigated for compliance with the applicable ARI requirements.

This equipment has been evaluated for safety when removing and recycling refrigerant in any condition from a system or storing it in an external container without necessarily testing or processing the refrigerant. The use of this equipment to reduce contaminants, such as moisture, oil, noncondensable gas, acidity, particulate matter and the like has been evaluated.

This equipment has been evaluated to meet EPA's minimum requirements in accordance with Section 608 of the Clean Air Act. Equipment manufactured after November 15, 1993 is provided with the auxiliary marking: "This Equipment Has Been Certified by Underwriters Laboratories To Meet EPA's Minimum Requirements for Recovery/Recycling Equipment Intended For Use With #."

- Indicates type(s) of refrigerant and type of appliance.

The basic standard used to investigate products in this category is UL 1963, "Refrigerant Recovery/Recycling Equipment." (SCKG)

The Listing Mark of Underwriters Laboratories Inc. on the product is the only method provided by UL to identify products manufactured under its Listing and Follow-Up Service. The Listing Mark for these products includes the name and/or symbol of Underwriters Laboratories Inc. (as illustrated in the Introduction of this Directory) together with the word "Listed," a control number, and the following product name: "Commercial Refrigerant Recovery/Recycling Equipment."

January 2011

VAN STEENBURGH ENGINEERING LABORATORIES, INC.

Type: Recovery/Recycling Dual Pass

| <u>Model Des-ignation</u> | <u>Refrigerant</u> | <u>Liquid Re-frigerant Recovery Rate (lbs/min)</u> | <u>Vapor Re-frigerant Recovery Rate (lbs/min)</u> | <u>Final Recovery Vacuum Level, in. Hg</u> | <u>Recycle Flow Rate (lbs/min)</u> | <u>Moisture Content (ppm by Weight)</u> | <u>Chloride Ions (ppm by Weight)</u> | <u>Acidity (ppm by Weight)</u> | <u>High Boiling Residue (% by Volume)</u> | <u>Parti-culates/Solids (Visual)</u> | <u>Non-Con-densable (% by Volume)</u> | <u>Non-Con-densable Purge Loss (≤ 5% by Weight)</u> |
|---------------------------|--------------------|--|---|--|------------------------------------|---|--------------------------------------|--------------------------------|---|--------------------------------------|---------------------------------------|---|
| BV300A-1 | R12 | 5.0 | 1.5 | 15 | 2.50 | 4.8 | Pass | < 0.1 | 0.009 | Pass | 0.1 | Pass |
| , -2 | R22 | 4.0 | 2.0 | 15 | 2.50 | 8.0 | Pass | < 0.1 | 0.007 | Pass | 0.1 | Pass |
| , -3 | R500 | 5.0 | 1.5 | 15 | 2.50 | 4.8 | Pass | < 0.1 | 0.01 | Pass | 0.63 | Pass |
| , -4 | R502 | 5.0 | 2.46 | 15 | 2.50 | 6.8 | Pass | < 0.1 | 0.01 | Pass | 0.41 | Pass |
| JV 90A -1 | R12 | 5.0 | 1.47 | 15 | 2.08 | 8.3 | Pass | < 0.1 | 0.005 | Pass | 0.81 | Pass |
| , -2 | R22 | 4.8 | 1.8 | 15 | 2.08 | 6.5 | Pass | < 0.1 | 0.007 | Pass | 1.02 | Pass |
| , -3 | R500 | 4.8 | 1.5 | 15 | 2.08 | 3.1 | Pass | < 0.1 | 0.007 | Pass | 0.24 | Pass |
| , -4 | R502 | 5.0 | 2.4 | 15 | 2.08 | 3.6 | Pass | < 0.1 | 0.005 | Pass | 0.40 | Pass |

Note: Tested in accordance with Appendix B in Sec. 608 of the Clean Air Act dated May 14, 1993.

January 2011

VAN STEENBURGH ENGINEERING LABORATORIES, INC.

Type: Recovery/Recycling Dual Pass

| <u>Model Designation</u> | <u>Refrigerant</u> | <u>Liquid Refrigerant Recovery Rate (lbs/min)</u> | <u>Vapor Refrigerant Recovery Rate (lbs/min)</u> | <u>Final Recovery Vacuum Level, in. Hg</u> | <u>Recycle Flow Rate (lbs/min)</u> | <u>Moisture Content (ppm by Weight)</u> | <u>Chloride Ions (ppm by Weight)</u> | <u>Acidity (ppm by Weight)</u> | <u>High Boiling Residue (% by Volume)</u> | <u>Particulates/Solids (Visual)</u> | <u>Non-Condensable (% by Volume)</u> | <u>Non-Condensable Purge Loss (≤ 5% by Weight)</u> |
|--------------------------|--------------------|---|--|--|------------------------------------|---|--------------------------------------|--------------------------------|---|-------------------------------------|--------------------------------------|--|
| LV30A-1 | R12 | 2.2 | 1.6 | 15 | 1.20 | 7.2 | Pass | < 0.1 | 0.01 | Pass | 0.44 | Pass |
| , -2 | R22 | 1.6 | 1.5 | 15 | 1.20 | 8.8 | Pass | < 0.1 | 0.007 | Pass | 0.28 | Pass |
| , -3 | R500 | 1.8 | 1.8 | 15 | 1.20 | 3.6 | Pass | < 0.1 | 0.005 | Pass | 0.9 | Pass |
| , -4 | R502 | 2.2 | 2.0 | 15 | 1.20 | 3.6 | Pass | < 0.1 | 0.005 | Pass | 0.45 | Pass |
| CV15A-1 | R12 | 2.3 | 1.0 | 15 | 0.95 | 3.6 | Pass | < 0.1 | 0.005 | Pass | 0.1 | Pass |
| , -2 | R22 | 1.7 | 1.0 | 15 | 0.95 | 13.1 | Pass | 0.3 | 0.008 | Pass | 0.29 | Pass |
| , -3 | R500 | 1.4 | 1.2 | 15 | 0.95 | 3.6 | Pass | < 0.1 | 0.005 | Pass | 0.28 | Pass |
| , -4 | R502 | 1.9 | 1.4 | 15 | 0.95 | 6.5 | Pass | < 0.1 | 0.005 | Pass | 0.18 | Pass |

NOTE: 1. For recovery-only units. "N/A" indicates not applicable.

2. For a recovery or recycle unit, a mass flow rate must be specified for liquid or vapor refrigerant or for both.

+ - Denotes manufacturer selected push/pull method of liquid recovery rating which may not be applicable in all fluid situations. Consult operating manual for applications.

++ - Denotes manufacturer selected rapid liquid recovery method. Consult operating manual for applications.

Note: Tested in accordance with Appendix B in Sec. 608 of the Clean Air Act dated May 14, 1993

January 2011

Commercial Refrigerant Recovery/Recycling Equipment Certified For Performance Characteristics In Accordance With Section 608 Of The United States Clean Air Act

This category covers commercial refrigerant recovery/recycling equipment that has been evaluated to meet the United States EPA's minimum performance requirements outlined in Sec. 608 of the Clean Air Act. These are covered under UL Category QVBC.

These products may also bear a UL Listing Mark as appropriate for the product type. For additional information of products that bear such Marks see UL's Electrical Appliance and Utilization Equipment Directory.

LOOK FOR THE CERTIFIED PERFORMANCE STATEMENT ON THE PRODUCT

The Certified Performance Marking of Underwriters Laboratories Inc. on the product is the only method provided by Underwriters Laboratories Inc. to identify products manufactured under its Certified Performance and Follow-up Service.

For those products which are also Listed, the Certified Performance Statement includes the appropriate Listing Mark and the statement: "This Equipment Has Been Certified by Underwriters Laboratories Inc. to Meet EPA's Minimum Requirements for (+) Equipment Intended for Use With (++)."

For those products which are not Listed, the Certified Performance Statement consists of: "This Equipment Has Been Certified by Underwriters Laboratories Inc. to Meet EPA's Minimum Requirements for (+) Equipment Intended for Use With (++)" and a control number. The symbol UL in a circle is not used as part of the marking.

- (+) – Recovery or Recovery/Recycling.
- (++) – Indicates type(s) of refrigerant and type of appliance.

January 2011

PUBLISHED PERFORMANCE RATINGS
RITCHIE ENGINEERING CO.

Type: Refrigerant Recovery Only Equipment

| Model Designation | Refrigerant | Push/Pull Recovery Rate (kg/min.) | Liquid Refrigerant Recovery Rate (kg/min) | Vapor Refrigerant Recovery Rate (kg/min) | High Temperature (40°C) | Final Recovery Level, kPa | Moisture Content (ppm by Weight) | Chloride Ions (ppm by Weight) | Acidity (ppm by Weight) | High Boiling Residue (% by Volume) | Non-Condensable Purge Loss (≤ 3% by Weight) | Refrigerant Loss, Weight % | Residual Trapped Refrigerant kg |
|-------------------|-------------|-----------------------------------|---|--|------------------------------|---------------------------|----------------------------------|-------------------------------|-------------------------|------------------------------------|---|----------------------------|---------------------------------|
| | | | | | Vapor Recovery Rate (kg/min) | | | | | | Purge Loss (≤ 3% by Weight) | | |
| R30, | R12 | 4.73 | N/A | 0.11 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | 3 | 0.05 |
| R30a | R134a | 4.23 | N/A | 0.09 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | 3 | 0.05 |
| R31 | R22 | 3.98 | N/A | 0.13 | 0.12 | 50.53 | N/A | N/A | N/A | N/A | N/A | 3 | 0.05 |
| 9570X | R500 | 4.38 | N/A | 0.11 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | 3 | 0.05 |
| | R502 | 3.45 | N/A | 0.11 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | 3 | 0.05 |
| R50, | R12 | 4.15 | 0.79 | 0.11 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | 3 | 0.05 |
| R50a, | R134a | 4.15 | 0.79 | 0.11 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | 3 | 0.05 |
| R53a, | R22 | 4.15 | 0.79 | 0.11 | 0.15 | 50.53 | N/A | N/A | N/A | N/A | N/A | 3 | 0.05 |
| 9575X | R500 | 4.15 | 0.79 | 0.11 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | 3 | 0.05 |
| | R502 | 4.17 | 1.05 | 0.19 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | 3 | 0.05 |
| R60, | R12 | 5.95 | 0.76 | 0.14 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | 3 | 0.05 |
| R60A, | R134a | 5.95 | 0.76 | 0.13 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | 3 | 0.05 |
| R62, | R22 | 5.95 | 0.76 | 0.15 | 0.14 | 50.53 | N/A | N/A | N/A | N/A | N/A | 3 | 0.05 |
| R62a, | R500 | 5.95 | 0.76 | 0.13 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | 3 | 0.05 |
| | R502 | 5.95 | 1.04 | 0.25 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | 3 | 0.05 |
| 95740 | R11 | 2.07 | 0.038 | 0.07 | N/A | >85.0 | N/A | N/A | N/A | N/A | N/A | 3 | 0.05 |
| | R123 | 2.07 | 0.038 | 0.07 | N/A | >85.0 | N/A | N/A | N/A | N/A | N/A | 3 | 0.05 |
| , | R114 | 2.07 | 0.038 | 0.07 | 0.14 | >85.0 | N/A | N/A | N/A | N/A | N/A | 3 | 0.05 |
| , | R407C | 5.39 | 0.75 | 0.43 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | 3 | 0.05 |
| R63 | R12 | 6.20 | 1.0 | 0.10 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | 3 | 0.05 |
| R63A, | R134a | 6.20 | 1.0 | 0.10 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | 3 | 0.05 |
| R73, | R22 | 6.20 | 1.0 | 0.10 | 0.13 | 50.53 | N/A | N/A | N/A | N/A | N/A | 3 | 0.05 |
| R73A | R500 | 6.20 | 1.0 | 0.10 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | 3 | 0.05 |
| | R502 | 6.23 | 1.38 | 0.18 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | 3 | 0.05 |
| R65 , 65a, | R12 | 4.98 | 0.9 | 0.14 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | 3 | 0.05 |
| R68, R68a, | R134a | 4.98 | 0.9 | 0.13 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | 3 | 0.05 |
| 95765, | R22 | 4.98 | 0.9 | 0.15 | 0.10 | 50.53 | N/A | N/A | N/A | N/A | N/A | 3 | 0.05 |
| 95768 | R500 | 4.98 | 0.9 | 0.13 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | 3 | 0.05 |
| | R502 | 5.0 | 1.24 | 0.25 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | 3 | 0.05 |

January 2011

PUBLISHED PERFORMANCE RATINGS

RITCHIE ENGINEERING CO.

Type: Refrigerant Recovery Only Equipment

| Model Designation | Refrigerant | Push/Pull Recovery Rate (kg/min.) | Liquid Refrigerant Recovery Rate (kg/min) | Vapor Refrigerant Recovery Rate (kg/min) | High Temperature (40°C) | Final Recovery Vacuum Level, kPa | Moisture Content (ppm by Weight) | Chloride Ions (ppm by Weight) | Acidity (ppm by Weight) | High Boiling Residue (% by Volume) | Non-Condensable Purge Loss | Refrigerant Loss, Weight % | Residual Trapped Refrigerant kg |
|-------------------------|-------------|-----------------------------------|---|--|------------------------------|----------------------------------|----------------------------------|-------------------------------|-------------------------|------------------------------------|----------------------------|----------------------------|---------------------------------|
| | | | | | Vapor Recovery Rate (kg/min) | | | | | | (≤ 3% by Weight) | | |
| R69, 95769 | R12 | 3.85 | 0.71 | 0.14 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | 3 | 0.05 |
| | R134a | 3.85 | 0.71 | 0.13 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | 3 | 0.05 |
| | R22 | 3.85 | 0.71 | 0.15 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | 3 | 0.05 |
| | R500 | 3.85 | 0.71 | 0.13 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | 3 | 0.05 |
| | R502 | 3.88 | 0.98 | 0.25 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | 3 | 0.05 |
| | R11 | 1.34 | 0.04 | 0.07 | N/A | >85.0 | N/A | N/A | N/A | N/A | N/A | 3 | 0.05 |
| | R123 | 1.34 | 0.04 | 0.07 | N/A | >85.0 | N/A | N/A | N/A | N/A | N/A | 3 | 0.05 |
| | R114 | 1.34 | 0.04 | 0.07 | N/A | >85.0 | N/A | N/A | N/A | N/A | N/A | 3 | 0.05 |
| R407C | 3.49 | 0.70 | 0.19 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | 3 | 0.05 | |
| R70, | R12 | 6.12 | 0.9 | 0.15 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | 3 | 0.05 |
| R70a, | R134a | 6.12 | 0.9 | 0.15 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | 3 | 0.05 |
| R72, | R22 | 6.12 | 0.9 | 0.15 | 0.15 | 50.53 | N/A | N/A | N/A | N/A | N/A | 3 | 0.05 |
| R72a, | R500 | 6.12 | 0.9 | 0.15 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | 3 | 0.05 |
| R82A | R502 | 6.16 | 1.2 | 0.27 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | 3 | 0.05 |
| R80a,9576X, 9577X. | R410A | 5.54 | 0.76 | 0.22 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | 3 | 0.05 |
| R100, 9510X | R12 | 6.39 | 1.68 | 0.17 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | 3 | 0.05 |
| | R134a | 6.82 | 1.59 | 0.14 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | 3 | 0.05 |
| | R22 | 7.65 | 1.68 | 0.24 | 0.23 | 50.53 | N/A | N/A | N/A | N/A | N/A | 3 | 0.05 |
| | R500 | 6.77 | 1.67 | 0.17 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | 3 | 0.05 |
| | R502 | 7.60 | 2.34 | 0.27 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | 3 | 0.05 |
| R100 (European Version) | R12 | 2.75 | 1.68 | 0.17 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | 3 | 0.05 |
| | R134a | 2.93 | 1.59 | 0.14 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | 3 | 0.05 |
| | R22 | 3.29 | 1.68 | 0.20 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | 3 | 0.05 |
| | R500 | 2.91 | 1.67 | 0.17 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | 3 | 0.05 |
| | R502 | 3.27 | 2.34 | 0.27 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | 3 | 0.05 |

Note: Tested in accordance with Appendix B in Sec. 608 of the Clean Air Act (proposed) dated February 29, 1996.

January 2011

PUBLISHED PERFORMANCE RATINGS
PUMP WORKS, INC.

Type: Refrigerant Recovery Unit

| <u>Model Designation</u> | <u>Refrigerant</u> | <u>PERCENT REFRIGERANT RECOVERED ($\geq 90\%$)</u> | | <u>PERCENT REFRIGERANT RECOVERED ($\geq 80\%$)</u> | |
|--------------------------|--------------------|---|--|---|---|
| | | <u>Operational Reciprocating Compressor</u> | <u>Operational Rotary Compressor</u> | <u>Nonoperational Reciprocating Compressor</u> | <u>Nonoperational Rotary Compressor</u> |
| Mongoose | R134a | Pass | Pass | Pass | Pass |

Note: Tested in accordance with Appendix C in Sec. 608 of the Clean Air Act dated May 14, 1993.

January 2011

PUBLISHED PERFORMANCE RATINGS
 APPION INC.

Type: Refrigerant Recovery Equipment Only

| Model Designation | Refrigerant | Push/Pull Recovery Rate (kg/min) | Liquid Recovery Rate (kg/min) | Vapor Recovery Rate (kg/min) | High Temp. | Final Recovery Vacuum Level KPa | Moisture Content (ppm by weight) | Chloride Ions (ppm by weight) | Acidity (ppm by weight) | High Boiling Residue (% by volume) | Non- Condensable Purge Loss (< 3% by Weight) | Refrigerant Loss, Weight % | Residual Trapped Refrigerant kg |
|----------------------|-------------|---|--|---------------------------------------|---------------------------------------|---|---|--|-------------------------------|--|--|----------------------------------|--|
| | | | | | Vapor Recovery Rate (kg/min) | | | | | | | | |
| G5 TWIN | R134A | 5.03 | 1.97 | 0.17 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | <0.05 |
| | R22 | 7.54 | 2.82 | 0.28 | 0.19 | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | <0.05 |
| | R407C | 7.99 | 3.18 | 0.23 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | <0.05 |
| | R410A | 4.63 | 1.58 | 0.18 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | <0.05 |
| G1 SINGLE | R134A | 4.28 | 2.36 | 0.10 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | <0.05 |
| | R22 | 4.90 | 3.88 | 0.12 | 0.14 | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | <0.05 |
| | R407C | 5.14 | 2.65 | 0.14 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | <0.05 |
| | R410A | 5.52 | 1.96 | 0.12 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | <0.05 |

January 2011

PUBLISHED PERFORMANCE RATINGS
CPS PRODUCTS, INC.

Type: Refrigerant Recovery Equipment Only

| Model Designation | Refrigerant | Push/Pull Recovery Rate (kg/min) | Liquid Recovery Rate (kg/min) | Vapor Recovery Rate (kg/min) | High Temp. | Final Recovery Vacuum Level KPa | Moisture Content (ppm by weight) | Chloride Ions (ppm by weight) | Acidity (ppm by Weight) | High Boiling Residue (% by volume) | Non- Condensable Purge Loss (< 3% by Weight) | Refrigerant Loss, Weight % | Residual Trapped Refrigerant kg |
|----------------------|-------------|---|--|---------------------------------------|---------------------------------------|---|---|--|-------------------------------|--|--|----------------------------------|--|
| | | | | | Vapor Recovery Rate (kg/min) | | | | | | | | |
| CR300 AR2700 | R12 | 4.72 | 0.33 | 0.10 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | <0.25 |
| | R134A | 4.34 | 0.33 | 0.09 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | <0.25 |
| | R22 | 4.12 | 0.20 | 0.10 | 0.10 | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | <0.25 |
| | R500 | 3.99 | 0.25 | 0.10 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | <0.25 |
| | R502 | 3.75 | 0.23 | 0.13 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | <0.25 |
| CR400 AR2700M | R12 | 4.72 | 0.33 | 0.10 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | <0.05 |
| | R134A | 4.34 | 0.33 | 0.09 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | <0.05 |
| | R22 | 4.12 | 0.20 | 0.10 | 0.10 | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | <0.05 |
| | R500 | 3.99 | 0.25 | 0.10 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | <0.05 |
| | R502 | 3.75 | 0.23 | 0.13 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | <0.05 |
| CR500 | R12 | 4.49 | 0.91 | 0.11 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | <0.05 |
| | R134A | 4.67 | 0.92 | 0.11 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | <0.05 |
| | R22 | 5.03 | 1.24 | 0.13 | 0.13 | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | <0.05 |
| | R500 | 5.17 | 1.01 | 0.12 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | <0.05 |
| | R502 | 5.53 | 1.37 | 0.17 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | <0.05 |
| CR600 | R12 | 4.30 | 1.18 | 0.10 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | <0.05 |
| | R134A | 4.89 | 1.00 | 0.10 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | <0.05 |
| | R22 | 5.30 | 0.87 | 0.14 | 0.13 | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | <0.05 |
| | R500 | 4.57 | 1.09 | 0.11 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | <0.05 |
| | R502 | 4.57 | 0.75 | 0.16 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | <0.05 |
| CR700 | R134A | 6.3 | 2.15 | 0.15 | N/A | 31.39 | N/A | N/A | N/A | N/A | N/A | N/A | <0.0071 |
| | R22 | 7.17 | 3.11 | 0.22 | 0.242 | 31.05 | N/A | N/A | N/A | N/A | N/A | N/A | <0.0071 |
| | R407C | 7.0 | 2.74 | 0.21 | N/A | 29.67 | N/A | N/A | N/A | N/A | N/A | N/A | <0.0071 |
| | R410A | 6.97 | 2.95 | 0.23 | N/A | 31.05 | N/A | N/A | N/A | N/A | N/A | N/A | <0.0071 |

January 2011

PUBLISHED PERFORMANCE RATINGS
VAN STEENBURGH ENGINEERING LABORATORIES, INC.

Type: Refrigerant Recovery Equipment Only

| Model Designation | Refrigerant | Push/Pull Recovery Rate (kg/min) | Liquid Recovery Rate (kg/min) | Vapor Recovery Rate (kg/min) | High Temp. | Final Recovery Level kPa | Moisture Content (ppm by weight) | Chloride Ions (ppm by weight) | Acidity (ppm by weight) | High | Non- | Refrigerant Loss, Weight % | Residual Trapped Refrigerant kg |
|----------------------|-------------|---|--|---------------------------------------|---|-----------------------------------|---|--|-------------------------------|--|--|----------------------------------|--|
| | | | | | (40°C) Vapor Recovery Rate (kg/min) | | | | | Boiling Residue (% by volume) | Condensable Purge Loss (< 3% by Weight) | | |
| RV-10 | R22 | N/A | 0.34 | 0.17 | 0.14 | 67.73 | N/A | N/A | N/A | N/A | N/A | N/A | 0.050 |
| | R134a | N/A | 0.52 | 0.13 | N/A | 71.11 | N/A | N/A | N/A | N/A | N/A | N/A | 0.045 |
| | R407C | N/A | 0.29 | 0.16 | N/A | 67.73 | N/A | N/A | N/A | N/A | N/A | N/A | 0.054 |

January 2011

PUBLISHED PERFORMANCE RATINGS
INFICON INC.

Type: Refrigerant Recovery Equipment Only

| Model Designation | Refrigerant | Push/Pull Recovery Rate (kg/min) | Liquid Recovery Rate (kg/min) | Vapor Recovery Rate (kg/min) | High Temp. | Final Recovery Vacuum Level kPa | Moisture Content (ppm by weight) | Chloride Ions (ppm by weight) | Acidity (ppm by weight) | High | Non- | Refrigerant Loss, Weight % | Residual Trapped Refrigerant kg |
|----------------------|-------------|---|--|---------------------------------------|---------------------------------------|---|---|--|-------------------------------|--|--|----------------------------------|--|
| | | | | | Vapor Recovery Rate (kg/min) | | | | | Boiling Residue (% by volume) | Condensable Purge Loss (< 3% by Weight) | | |
| Vortex AC | R22 | 5.37 | 1.35 | 0.13 | 0.13 | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | 0.0 |
| | R134a | 3.44 | 1.13 | 0.10 | - | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | 0.0 |
| | R407C | 5.13 | 1.85 | 0.11 | - | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | 0.0 |
| | R410A | 5.15 | 1.57 | 0.13 | - | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | 0.0 |

January 2011

PUBLISHED PERFORMANCE RATINGS
SPX CORP

Type: Refrigerant Recovery Equipment Only

| Model Designation | Refrigerant | Push/Pull Recovery Rate (kg/min) | Liquid Recovery Rate (kg/min) | Vapor Recovery Rate (kg/min) | High Temp. | Final Recovery Vacuum Level kPa | Moisture Content (ppm by weight) | Chloride Ions (ppm by weight) | Acidity (ppm by Weight) | High Boiling Residue (% by volume) | Non- Condensable Purge Loss (< 3% by Weight) | Refrigerant Loss, Weight % | Residual Trapped Refrigerant kg |
|---------------------------|-------------|---|--|---------------------------------------|---------------------------------------|---|---|--|-------------------------------|--|--|----------------------------------|--|
| | | | | | Vapor Recovery Rate (kg/min) | | | | | | | | |
| RG5410A and RG5410A-KT | R134A | 3.63 | 1.57 | 0.11 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | <0.05 |
| | R22 | 4.32 | 1.81 | 0.15 | 0.15 | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | <0.05 |
| | R407C | 4.32 | 1.81 | 0.15 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | <0.05 |
| | R410A | 4.91 | 1.85 | 0.16 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | <0.05 |
| RG5410HP | R134A | 4.05 | 1.46 | 0.12 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | <0.05 |
| | R22 | 4.64 | 1.28 | 0.14 | 0.15 | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | <0.05 |
| | R407C | 4.64 | 1.28 | 0.14 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | <0.05 |
| | R410A | 4.90 | 1.7 | 0.17 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | <0.05 |
| MINIMAX and MINIMAX-KT | R134A | 4.53 | 1.03 | 0.11 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | <0.05 |
| | R22 | 5.67 | 1.22 | 0.13 | 0.15 | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | <0.05 |
| | R407C | 5.67 | 1.22 | 0.13 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | <0.05 |
| | R410A | 5.90 | 1.50 | 0.15 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | <0.05 |
| 25150B (Robinair) | R134A | 5.13 | 1.01 | - | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | <0.05 |
| | R22 | 5.87 | 1.22 | - | 0.15 | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | <0.05 |
| | R407C | 5.87 | 1.22 | - | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | <0.05 |

January 2011

PUBLISHED PERFORMANCE RATINGS
SPX CORP

Type: Refrigerant Recovery Equipment Only

| Model Designation | Refrigerant | Push/Pull Recovery Rate (kg/min) | Liquid Recovery Rate (kg/min) | Vapor Recovery Rate (kg/min) | High Temp. | Final Recovery Vacuum Level Kpa | Moisture Content (ppm by weight) | Chloride Ions (ppm by weight) | Acidity (ppm by Weight) | High Boiling Residue (% by volume) | Non- Condensable Purge Loss (< 3% by Weight) | Refrigerant Loss, Weight % | Residual Trapped Refrigerant kg |
|----------------------|-------------|---|--|---------------------------------------|---|---|---|--|-------------------------------|--|--|----------------------------------|--|
| | | | | | High Temp. (40°C) Vapor Recovery Rate (kg/min) | | | | | | | | |
| 25175B | R134A | 3.55 | 1.55 | 0.10 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | <0.05 |
| | R22 | 4.21 | 1.75 | 0.13 | 0.17 | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | <0.05 |
| | R407C | 4.21 | 1.75 | 0.13 | N/A | 50.5 3 | N/A | N/A | N/A | N/A | N/A | N/A | <0.05 |
| | R410A | 4.74 | 1.75 | 0.15 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | <0.05 |
| 25200B | R134A | - | 0.73 | 0.06 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | <0.05 |
| | R22 | - | 0.68 | 0.06 | 0.06 | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | <0.05 |
| | R407C | - | 0.68 | 0.06 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | <0.05 |
| | R410A | - | 0.30 | 0.06 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | <0.05 |
| Pro Vax | R134A | 3.63 | 1.57 | 0.11 | N/A | 53.53 | N/A | N/A | N/A | N/A | N/A | <3 | <0.05 |
| | R22 | 4.32 | 1.81 | 0.15 | 0.15 | 53.53 | N/A | N/A | N/A | N/A | N/A | <3 | <0.05 |
| | R407C | 4.32 | 1.81 | 0.15 | N/A | 53.53 | N/A | N/A | N/A | N/A | N/A | <3 | <0.05 |
| | R410A | 4.91 | 1.85 | 0.16 | N/A | 53.53 | N/A | N/A | N/A | N/A | N/A | <3 | <0.05 |
| RG5410EX | R134A | 5.32 | 1.10 | 0.144 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | <0.05 |
| | R22 | 6.60 | 1.90 | 0.185 | 0.141 | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | <0.05 |
| | R407C | 5.20 | 1.20 | 0.155 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | <0.05 |
| | R410A | 6.41 | 2.33 | 0.201 | N/A | 50.53 | N/A | N/A | N/A | N/A | N/A | N/A | <0.05 |
| RG6000 | R134a | 5.05 | 2.29 | 0.18 | N/A | 50.48 | N/A | N/A | N/A | N/A | N/A | <3 | <0.05 |
| | R22 | 7.13 | 3.53 | 0.25 | 0.21 | 50.29 | N/A | N/A | N/A | N/A | N/A | <3 | <0.05 |
| | R407C | 7.26 | 3.15 | 0.24 | N/A | 50.45 | N/A | N/A | N/A | N/A | N/A | <3 | <0.05 |
| | R410A | 7.60 | 2.74 | 0.16 | N/A | 50.25 | N/A | N/A | N/A | N/A | N/A | <3 | <0.05 |

January 2011

PUBLISHED PERFORMANCE RATINGS
NATIONAL REFRIGERATION PRODUCTS

| Model Dsg | Refrigerant | Push/Pull Recovery Rate (kg/min) | Liquid Recovery Rate (kg/min) | Vapor Recovery Rate (kg/min) | Final Recovery Vacuum Level kPa | Moisture Content (ppm by weight) | Chloride Ions (ppm by weight) | Acidity (ppm by weight) |
|--------------|-------------|--|--|---------------------------------------|---|--|--|----------------------------------|
| GS3700 | R22(+) | 7.17 | 3.11 | 0.22 | 31.05 | N/A | N/A | N/A |
| | R410A(+) | 6.97 | 2.95 | 0.23 | 31.05 | N/A | N/A | N/A |
| | R407C(+) | 7.0 | 2.74 | 0.21 | 29.67 | N/A | N/A | N/A |
| | R134A(+) | 6.3 | 2.15 | 0.15 | 21.39 | N/A | N/A | N/A |

Note: (High temperature vapor flow rate kg/min=0.242, Residual trapped refrigerant kg=0.0071).

* - Product identification, construction variations, ratings and performance data.

+ - Represents refrigerants in Categories III, IV, V ARI-740 – 1998.

January 2011

PUBLISHED PERFORMANCE RATINGS
THERMAFLO, DIV. OF REFCO MFG. (US) INC.

Type: Refrigerant Recovery Equipment Only

| Model Designation | Refrigerant | Push/Pull Recovery Rate <u>kg/min.</u> | Liquid Recovery Rate <u>kg/min.</u> | Vapor Recovery Rate <u>kg/min.</u> | High Temp. (40°C) | Final Recovery Vacuum Level <u>Kpa</u> | Moisture Content (ppm by <u>weight</u>) | Chloride Ions (ppm by <u>weight</u>) | Acidity (ppm by <u>weight</u>) | High Boiling Residue (% by <u>volume</u>) | Residual Trapped Refrigerant <u>kg</u> |
|----------------------|-------------|---|--|---|---|--|---|--|---------------------------------------|--|---|
| | | | | | Vapor Recovery Rate <u>kg/min.</u> | | | | | | |
| Powermax 600 | R12 | 4.64 | 1.70 | 0.19 | N/A | >50.53 | N/A | N/A | N/A | N/A | <0.11 |
| | R22 | 5.36 | 2.04 | 0.23 | N/A | >50.53 | N/A | N/A | N/A | N/A | N/A |
| | R134a | 5.46 | 1.92 | 0.23 | N/A | >50.53 | N/A | N/A | N/A | N/A | N/A |
| | R410a | 7.96 | 2.26 | 0.24 | N/A | >50.53 | N/A | N/A | N/A | N/A | N/A |
| | R500 | 5.32 | 1.80 | 0.19 | N/A | >50.53 | N/A | N/A | N/A | N/A | <0.11 |
| | R502 | 5.76 | 2.36 | 0.28 | N/A | >50.53 | N/A | N/A | N/A | N/A | <0.11 |

v:\News and Notes

