



Lead

Please read all the instructions before sampling to ensure proper test results.

Before Sampling

- Your sampling kit contains the bottles marked below.
- 6 to 8 hours prior to sampling flush the cold water sampling line for approximately 10 minutes.
- The system should remain undisturbed for a period of at least 6 hours but not more than 8 hours.

Sampling Steps

1. Collect the **first** water as the tap is opened (after sitting undisturbed for 6 to 8 hours).
2. Fill bottle(s) to the neck.
3. Indicate sampling date, time, site, and name of sampler on both the bottle labels and the enclosed Chain of Custody. Information on the Chain of Custody and labels must match and be complete.

Shipping Instructions

- Return bottles to the laboratory within 14 days of collection to ensure accurate test results.
- Samples do not need to be cold.
- Hand deliver samples to the laboratory or ship samples by a carrier service.



Quantity

Call 1.574.233.4777 or 1.800.332.4345 or visit us at www.ul.com/water
UL, 110 S. Hill Street, South Bend, IN 46617