

## Security Listing Mark Data Page

(FILE IMMEDIATELY AFTER AUTHORIZATION PAGE)

SECURITY LISTING MARK

The Security Listing Mark consists of five elements placed in close proximity and shall appear on Listed products only. Minimum size is not specified, as long as the Mark is legible. The following is suggested:



XXXX = The control number assigned by UL,

The minimum height of the registered trademark symbol ® shall be 3/64 of an inch. When the overall diameter of the UL Mark is less than 3/8 of an inch, the trademark symbol may be omitted if it is not legible to the naked eye.

The product identity is "EQUIPMENT" or "SUBASSEMBLY" as appropriate.

PRODUCTS ALSO LISTED TO ENERGY MANAGEMENT, ITE, TELEPHONE OR MISC. SIGNALING

Products that are also Listed by UL to Energy Management, Information Technology, Telephone and Miscellaneous Signaling requirements must include the product identity "ENCLOSED ENERGY MANAGEMENT," "INFORMATION TECHNOLOGY," "TELEPHONE," or "GENERAL SIGNALING" as appropriate, along with "SECURITY" followed by "EQUIPMENT" or "SUBASSEMBLY" as appropriate. If more than one is applicable, the text shall be separated by a comma.

PRODUCTS ALSO LISTED TO SIGNALING REQUIREMENTS

Products that are also Listed by UL to Signaling requirements shall substitute the logo above with one that incorporates reference to both Security and Signaling as shown below. However, the appropriate product identity for the Signaling application must be included as part of the Mark.



The product identity for Security and Signaling includes "FIRE ALARM," "HOSPITAL SIGNALING AND NURSE CALL," or "EMERGENCY SIGNALING" as appropriate, along with "SECURITY" followed by "EQUIPMENT" or "SUBASSEMBLY" as appropriate. If more than one is applicable, the text shall be separated by a comma.

ALTERNATIVE MARKING METHODS

The complete Listing Mark may appear on the smallest unit container in which the product is packaged when the product is of such a size, shape, material or surface texture that makes it impossible to incorporate the complete Listing Mark on the product.

The product identity may be abbreviated by a Type designation as shown below. The word "TYPE:" followed by the appropriate Type designation will be required to appear adjacent to the UL Mark. Multiple Type designations shall be separated by a comma. The Type designation shall be followed by the word "SUBASSEMBLY" as appropriate.

TYPE

S	Security Equipment (optional for Security only type products)
F	Fire Alarm Equipment
HN	Hospital Signaling and Nurse Call Equipment
G	General Signaling Equipment
E	Emergency Signaling Equipment
EM	Enclosed Energy Management Equipment
IT	Information Technology Equipment
T	Telephone Equipment

PROCUREMENT

The manufacturer may reproduce the Mark or obtain it from a UL authorized supplier. The list of UL authorized label suppliers can be found on UL's online directory at [www.ul.com](http://www.ul.com).