

CORRELATION OF USE MARKING AND NEW PRODUCT IDENTITY TEXT

The Product Identity of the Listing Mark for products in this file has been revised with the transition to the new Product Identity to be completed by December 31, 2008. In conjunction with the implementation of the new Type R Listing Mark Product Identity covered on the new Listing Mark Data Page(s), which have been added to this File, it is required that the use marking described below is employed on *each model* at the time the new Type R Marks are introduced. The products are eligible to use the previous Listing Mark Product Identity until December 31, 2008.

Each unit shall be marked with the applicable use marking indicated in the table below followed by the specific use description covered in the description section for the unit.

The following table correlates the new required use marking with the product identity (Listing Mark text) of the previous Type R Listing Mark. If more than one product identity was previously applicable, the new use marking texts shall be combined (See below for examples).

CCN	Previous Product Identity for Type R label Text	New Product Identity for Type R Listing Mark	New Required Use Marking Examples
ALVY	"Access Control Unit" or appropriate product identities, as shown in the individual Listing	"Equipment"	"Access Control Unit" or appropriate product identities, as shown in the description section of the report.
ALVY	"Access Control Unit Subassembly", "Access Control System Subassembly" or "Access Control System Enclosure" or "Access Control Unit Enclosure," or "Access Control System Enclosure Part" or "Access Control Unit Enclosure Part" or the specific product name or designation as shown in the individual Listings	"Subassembly"	"Access Control Unit" or appropriate product identities, as shown in the description section of the report. Examples: Access Control Unit Enclosure, Access Control Unit Keypad, etc

AMCX/AMCX7, AOTX/AOTX7, APAW/APAW7, APOU/APOU7	"Burglar Alarm System Control Unit"	"Equipment" or "Subassembly"	"Access Control" and the specific product name or designation covered in the description section for the unit.
APHV/APHV7	"Burglar Alarm System Power Supply" or the specific product name or designation as shown in the individual Listings	"Equipment" or "Subassembly"	The specific product name or designation covered in the description section for the unit.
ATJT	"Antitheft Alarm" or "Antitheft Device" or the specific product name or designation as shown in the individual Listings	"Equipment" or "Subassembly"	"Antitheft Alarm" or "Antitheft Device" or the specific product name or designation covered in the description section for the unit.
CVXJ	"Burglary-Resistant Electrically Operated Door Locking Mechanism" or the specific product name or designation as shown in the individual Listings.	"Equipment" or "Subassembly"	"Burglary-Resistant" and the specific product name or designation as covered in the description section for the unit.
CVYR	"Burglary-Resistant Electric Locking Mechanism Accessory" or the specific product name or designation as shown in the individual Listings.	"Equipment" or "Subassembly"	"Burglary-Resistant" and the specific product name or designation as covered in the description section for the unit.

DRQH	"COMMERCIAL CCTV EQUIPMENT", "COMMERCIAL CCTV PRODUCT", "COMMERCIAL CCTV VIDEO EQUIPMENT", "COMMERCIAL CCTV VIDEO PRODUCT", or other product identities, as shown in the individual Listing PREFIXED BY "COMMERCIAL" OR "COMMERCIAL USE".	"Equipment" or "Subassembly"	The specific product name or designation covered in the description section for the unit.
FULA/FULA7	"CONTROLLED EXIT PANIC DEVICE"	"Equipment" or "Subassembly"	"Controlled Exit Panic Device " and the specific product name or designation covered in the description section for the unit.
NBSX	"HOUSEHOLD BURGLAR ALARM SYSTEM UNITS" or appropriate product identities, as shown in the individual Listing.	"Fire Alarm Equipment" or "Fire Alarm Subassembly"	"Residential" or "Household" and the specific product name or designation covered in the description section for the unit.
PAZX	"Enclosed Energy Management Equipment"	"Enclosed Energy Management Equipment"	The specific product name or designation covered in the description section for the unit.

PAZX	"Enclosed Energy Management Equipment Subassembly," "Enclosed Energy Management Equipment Enclosure," or "Enclosed Energy Management Equipment Enclosure Part"	"Enclosed Energy Management Subassembly"	The specific product name or designation covered in the description section for the unit.
SZNT/SZNT7	"Releasing Device"	"Fire Alarm Equipment"	"Releasing Device"
SZNT/SZNT7	"Releasing Device Subassembly"	"Fire Alarm Subassembly"	Key subassembly use marking will include the following: "Releasing Device"
UEHX/UEHX7	"Signal Appliance"	"Emergency Signaling Equipment" for products rated Type UM, SM, and AM or critical process monitoring. "General Signaling Equipment" for units rated Type NM or non-critical monitoring. Note: Ratings are covered in description section for product. Products may have one or both ratings.	Use marking [Type NM, UM, SM, or AM] included in description section for unit. Key subassembly use marking will include the following: Use marking [Type NM, UM, SM, or AM] included in description section for unit.

UEHX/UEHX7	<p>"Signal Appliance Subassembly," "Signal Appliance Enclosure," and "Signal Applaince Enclsoure Part"</p>	<p>"Emergency Signaling Subassembly" for products rated Type UM, SM, and AM or critical process monitoring. "General Signaling Subassembly" for units rated Type NM or non-critical monitoring.</p> <p>Note: Ratings are covered in description section for product. Products may have one or both ratings.</p>	<p>Key subassembly use marking will include the following: Use marking [Type NM, UM, SM, or AM] included in description section for unit.</p>
UOJZ/UOJZ7	<p>"Signal System Control Unit"</p>	<p>"Fire Alarm Equipment"</p>	<p>Each unit shall be marked "Commercial Fire," the applicable use marking indicated for the complementary Listed categories, and either "Protected Premise Control Unit" or "Supervising Station Control Unit," as covered in the description section for the unit.</p>

UOJZ/UOJZ7	"Signal System Control Unit Subassembly", "Signal System Control Unit Enclosure", or "Signal System Control Unit Enclosure Part"	"Fire Alarm Subassembly"	All subassemblies marked "Commercial Fire" Key subassembly use marking will include the following: "Commercial," the applicable use marking indicated for the complementary Listed categories, and either "Protected Premise Control Unit" or "Supervising Station Control Unit," as covered in the description section for the unit.
------------	--	--------------------------	---