

CORRELATION OF USE MARKING AND PRODUCT IDENTITY TEXT FOR NEW TYPE R LISTING MARKS

The service for products in this file is transitioning from Type L to Type R with transition to be completed by December 31, 2008. In conjunction with the implementation of the new Type R Listing Mark Text covered on the Listing Mark Data Page(s) which have been added to this File, it is required that the use marking and product identity described below is employed on *each model* at the time the new Type R Marks are introduced.

The products are eligible to use the applicable Type L Listing Marks covered in this Section General until December 31, 2008.

Each control unit shall be marked with the use marking indicated in the table below. Where the product is comprised entirely of labeled subassemblies, the use marking is to be applied to a subassembly used exclusively for the product and employed in every installation. [The subassembly which employs all the required marking is identified in the marking portion of the description section for the product.] Use marking is not required for the remaining labeled subassemblies. With respect to Subassemblies, only the models that are referenced later in this Section General are eligible to bear the Listing Mark.

The following table correlates the new required use marking with the product identity (Listing Mark text) of the previous Type L Listing Mark. Please refer to the Type L Listing Mark section shown below this table for information to assist in the use of this table. If more than one product identity was previously applicable, the new use marking texts shall be combined.

CCN	Product Identity Included in Former Type L label Text	New Product Identity for Type R Listing Mark	New Required Use Marking
FSZI	"Emergency Signaling Control Unit"	"Emergency Signaling Equipment"	Specific use marking (i.e. Type UM, Type SM, Type AM, control unit, supervising station unit, etc.) included in description section for unit.
FSZI	"Emergency Signaling Control Unit Subassembly", "Emergency Signaling Control Unit Enclosure", or "Emergency Signaling Control Unit Enclosure Part"	"Emergency Signaling Subassembly"	None, except when key subassembly as noted below. Key subassembly use marking will include information indicated above for the overall control unit.