



PUBLIC NOTICE

Release No. 19PN-15

Michelle Press
Communications Director
UL LLC
847.664.1966
Michelle.Press@ul.com

UL Warns of Counterfeit UL Marks on Fire Sprinklers (Release 19PN-15)

NORTHBROOK, Ill., August 30, 2019 - The following is a notification from UL that the fire sprinkler identified below bears a counterfeit UL Certification Mark for the United States. The fire sprinkler has not been evaluated by UL to the appropriate Standards for Safety and it is unknown if they comply with any safety requirements.

Name of Product: Model 15SSSP

Remedy: UL recommends that these products be immediately removed from service and be replaced by UL Certified Fire Sprinklers.

Identification on the Product: The products are marked with a counterfeit UL Certification Marks, "ANGUS" and "2016" on the wrench boss. The following is marked on the deflector:

15SSP
68°C / 155°F



Photographs of the product:



Location: These counterfeit fire sprinklers were found in Mexico City, they may have been distributed at other locations.

About UL:

UL helps create a better world by applying science to solve safety, security and sustainability challenges. We empower trust by enabling the safe adoption of innovative new products and technologies. Everyone at UL shares a passion to make the world a safer place. All of our work, from independent research and standards development, to testing and certification, to providing analytical and digital solutions, helps improve global well-being. Businesses, industries, governments, regulatory authorities and the public put their trust in us so they can make smarter decisions. To learn more, visit [UL.com](https://www.ul.com).