

PUBLIC NOTICE

Release No. 20PN-24

Amy Patti Communications Director UL LLC 847.664.8480 Amy.Patti@ul.com

UL Warns of Counterfeit UL Mark on Fire Doors and Fire Door/Window Frames (Release 20PN-24)

NORTHBROOK, III., September 30, 2020 - The following is a notification from UL that the UL Mark identified below is counterfeit and might have been applied on fire doors and fire door/window frames. Fire doors and fire door/window frames bearing the counterfeit certification mark have not been evaluated by UL to the appropriate Safety Standards for the risk of fire, electric shock, or injury to persons and it is unknown if they comply with any safety requirements.

Remedy: UL recommends that these products be removed from service and be replaced with UL certified fire doors and fire door/window frames.

Identification on the label:

The label has a counterfeit UL Certification Mark and the following:



DO NOT REMOVE OR COVER THIS LABEL

LISTED FIRE DOOR / FRAME

Photograph:



Location: The counterfeit UL Mark labels might have been applied on fire doors and fire door/window frames installed in the Kingdom of Saudi Arabia.

About UL

UL helps create a better world by applying science to solve safety, security and sustainability challenges. We empower trust by enabling the safe adoption of innovative new products and technologies. Everyone at UL shares a passion to make the world a safer place. All of our work, from independent research and standards development, to testing and certification, to providing analytical and digital solutions, helps improve global well-being. Businesses, industries, governments, regulatory authorities and the public put their trust in us so they can make smarter decisions. To learn more, visit <u>UL.com</u>. To learn more about our nonprofit activities, visit <u>UL.org</u>.